

WELCH AUDITORIUM
RECOMMENDED CITATIONS

Erhardt Construction

Citation/ Item	Classification	Standard No.	Rule No. & Rule	Description	Proposed Penalty
1	Serious	Part 20	408.42031(9) During demolition, an employer or his or her designated representative shall make daily inspections to detect hazards and unsafe conditions. An employer shall ensure that an employee is not permitted to work where hazards exist until the hazards are corrected by shoring, bracing, or other effective means.	Employer did not make effective inspection of work area.	\$5,000.00
2	Serious	Part 20	408.42033(1) When an employee is required to be inside a structure being demolished, only a means of egress designated by the employer shall be used and maintained. All other means shall be closed off.	Employees had multiple means of egress in which to access the work area.	\$5,000.00
3	Serious	Part 20	408.42033(3) A means of egress shall be guarded to protect an employee from falling material.	Employee was buried by falling debris.	\$5,000.00
4	Serious	Part 20	408.42045(4) Only those employees necessary to the operation of mechanical demolition equipment shall be permitted in the demolition area at any time.	Employees work operations not necessary to mechanical demolition equipment operation.	\$5,000.00

WELCH AUDITORIUM
RECOMMENDED CITATIONS

Erhardt/Hunt, A Joint Venture

1	Serious	Part 20	408.42031(9) During demolition, an employer or his or her designated representative shall make daily inspections to detect hazards and unsafe conditions. An employer shall ensure that an employee is not permitted to work where hazards exist until the hazards are corrected by shoring, bracing, or other effective means.	Employer did not make effective inspection of work area.	\$5,000.00
2	Serious	Part 20	408.42033(1) When an employee is required to be inside a structure being demolished, only a means of egress designated by the employer shall be used and maintained. All other means shall be closed off.	Employees had multiple means of egress in which to access the work area.	\$5,000.00
3	Serious	Part 20	408.42033(3) A means of egress shall be guarded to protect an employee from falling material.	Employee was buried by falling debris.	\$5,000.00
4	Serious	Part 20	408.42045(4) Only those employees necessary to the operation of mechanical demolition equipment shall be permitted in the demolition area at any time.	Employees work operations not necessary to mechanical demolition equipment operation.	\$5,000.00

WELCH AUDITORIUM
RECOMMENDED CITATIONS

Hunt Construction Group

1	Serious	Part 20	408.42031(9) During demolition, an employer or his or her designated representative shall make daily inspections to detect hazards and unsafe conditions. An employer shall ensure that an employee is not permitted to work where hazards exist until the hazards are corrected by shoring, bracing, or other effective means.	Employer did not make effective inspection of work area.	\$5,000.00
2	Serious	Part 20	408.42033(1) When an employee is required to be inside a structure being demolished, only a means of egress designated by the employer shall be used and maintained. All other means shall be closed off.	Employees had multiple means of egress in which to access the work area.	\$5,000.00
3	Serious	Part 20	408.42033(3) A means of egress shall be guarded to protect an employee from falling material.	Employee was buried by falling debris.	\$5,000.00
4	Serious	Part 20	408.42045(4) Only those employees necessary to the operation of mechanical demolition equipment shall be permitted in the demolition area at any time.	Employees work operations not necessary to mechanical demolition equipment operation.	\$5,000.00

WELCH AUDITORIUM RECOMMENDED CITATIONS

Pitsch Companies

1	Serious	Part 20	408.42031(9) During demolition, an employer or his or her designated representative shall make daily inspections to detect hazards and unsafe conditions. An employer shall ensure that an employee is not permitted to work where hazards exist until the hazards are corrected by shoring, bracing, or other effective means.	Employer did not make effective inspection of work area.	\$5,000.00
---	---------	---------	---	--	------------

Allied Electric

1	Serious	Part 20	408.42031(9) During demolition, an employer or his or her designated representative shall make daily inspections to detect hazards and unsafe conditions. An employer shall ensure that an employee is not permitted to work where hazards exist until the hazards are corrected by shoring, bracing, or other effective means.	Employer did not make effective inspection of work area.	\$1,500.00
2	Serious	Part 20	408.42033(1) When an employee is required to be inside a structure being demolished, only a means of egress designated by the employer shall be used and maintained. All other means of egress shall be closed off.	Employees had multiple means of egress into work area.	\$1,500.00
3	Serious	Part 20	408.42045(4) Only those employees necessary to the operation of mechanical demolition equipment shall be permitted in the demolition area at any time.	Employees engaged in electrical work operations not necessary to mechanical demolition equipment operation.	\$1,500.00